



### SANITARY CERTIFICATE

(Issued under Tamilnadu Public Health Act 1939 and Table-10 under The Tamil Nadu District Municipalities Building Rules, 1972)

Sub : Public Buildings - Schools and Institutions - Sanitary Certificate issued to M/S. GNANA VIDYA MANDIR SENIOR SECONDARY SCHOOL, KEELAKATTUVILAI, MANIKATTIPOTTAL POST - 629501

Ref.:1. Application dated : 03.02.2026 ROC No.2028/2026/H3

2. Inspection dated : 10.02.2026

With reference to the above, I hereby declare that, I have inspected the building premises of M/S. GNANA VIDYA MANDIR SENIOR SECONDARY SCHOOL, KEELAKATTUVILAI, MANIKATTIPOTTAL POST - 629501 . on 10.02.2026, the accommodation provided is properly ventilated and lighted; that the building is maintained in substantial repair; that it is neat and clean; that the latrine arrangements are adequate and satisfactory; that the supply of drinking water is wholesome and all other aspects of sanitation are satisfactory.

This certificate is issued subject to the following conditions:

1. The garbage and sanitary Napkin wastes generated within the premises should be collected and disposed properly in segregated manner as per rules. On any account the wastes should not be burnt or disposed in public garbage disposal points.
2. The garbage generated within the premises should be collected and disposed properly in segregated manner as per SWM 2016 (50-ltr Green & Blue Dustbin for wet and dry waste).
3. A clean, Rat proof store room must be provided for Canteen or mess.
4. NO SMOKING signage should be displayed as per COTP Act 2003.
5. Information board for BAN ON SINGLE USAGE OF PLASTICS in the premises should be displayed.
6. Fire precautionary measures should be maintained properly.
7. Child labour should not be engaged on any account.
8. Door, Windows, Walls, and Grills should be painted yearly once.
9. Water Tank/Sintex Tank should be cleaned with bleaching powder every once in two months.
10. Shall not cause nuisance to public as per definition under The Tamil Nadu Public Health Act, 1939.
11. Should provide safe and wholesome Drinking Water.
12. Western toilets should be constructed for physically disabled/Elderly persons should be provided at a ratio of 3:1 (3-Indian Toilet, 1-Western Toilet).
13. To Keep TOBACCO-IEC and to get "TOBACCO FREE ZONE" Certificate from Corporation.
14. Yellow line should be drawn for every 100feet/200feet/300feet Maintaining to be free zone from school entrance road
15. This certificate issued is valid for one year (Till 09.02.2027) only from the date of issue.

This certificate is liable to be cancelled at anytime on infringement of any of the above conditions or for improper maintenance of the building or toilets in the premises.

*C. Chandra Kala*  
C. CHANDRA KALA  
Date 10.02.2026  
GNANA VIDYA MANDIR  
KEELAKATTUVILAI  
KANYAKUMARI DISTRICT  
PIN: 629 501

*R. Rajaram*  
10/2/2026  
R. Rajaram  
CITY HEALTH OFFICER  
NAGERCOIL CORPORATION  
Correspondent



# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

Post Office Upstair, Medical College Road,

Asaripallam, Nagerecoil - 629201

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com

### TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No:	TR/2025/50739	Report Issue Date :	04.06.2025	Page No.01 of 02
Invoice Details:	10939/Dt.29.05.2025/ Rs.1,652/			

Customer Name & Address Contact No / Email.ID	: Gnaana Vidya Mandir Senior Secondary CBSE School, Keelakattuvilai, Manikettipottal.
Sample Name	: Water
Sample Description	: Drinking Water (Bore well water)
Sample Submitted by	: Gnaana Vidya Mandir Senior Secondary CBSE School,
Location & Date	: Keelakattuvilai
Quantity of sample Received	: 2 Litres
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 29.05.2025
Test Commenced on	: 29.05.2025
Test Completed on	: 04.06.2025
Environmental Condition	: 24.5 <sup>o</sup> C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH	IS 3025 Part 11-2022	-	7.48	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO <sub>3</sub>	IS 3025 Part 21-2009 (RA 2019)	mg/L	8	200	600
3	Total Alkalinity	IS 3025-Part 23-2023	mg/L	12	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA 2019)	mg/L	12	250	1000
5	Sulphate as SO <sub>4</sub>	IS 3025-Part 24-2022(Turbidity Method)	mg/l.	<5	200	400
6	Nitrate as NO <sub>3</sub>	APHA 2.1 <sup>th</sup> Edition 2023 - 4500 -NO3 B	mg/L	<2	45	45
7	Fluoride as F	APHA 2.1 <sup>th</sup> Edition 2023 - 4500- F-D	mg/L	0.2	1.0	1.5

**Remarks:** The tested sample confirmed to IS: 10500:2012 (RA 2019) Drinking water Acceptable limit specification with respect to above tested parameters.

C. Chandra Kala

CHANDRAKALA

PRINCIPAL

GNANA VIDYA MANDIR

KEELAKATTUVILAI

C.Ananthi - Assistant Executive Engineer  
5/6/25  
For GNANA VIDYA MANDIR  
R. Rajaramya

Correspondent



## SANITARY CERTIFICATE

Issued under Appendix 3 Chapter III Rule 21 under The Tamil Nadu Educational Rules and Table 10 under The Tamil Nadu District Municipalities Building Rules, 1974  
Sub: Schools - Sanitary Certificate issued to GNANA VIDYA MANDIR SENIOR SECONDARY SCHOOL, KEELAKATTUVILAI, MANIKATTIPOTTAL POST - 629501.

- Ref.: 1. Application dated: 22.11.2024; ROC No. 17572/2024/H3  
2. Inspection dated: 10.11.2024

With reference to the above, I hereby declare that the accommodation provided in GNANA VIDYA MANDIR SENIOR SECONDARY SCHOOL, KEELAKATTUVILAI, MANIKATTIPOTTAL POST - 629501 for each of the several classes for the minimum number of pupils taught therein is properly ventilated and lighted; that the building is maintained properly; that it is neat and clean; that the latrine arrangements are adequate and satisfactory; that the supply of drinking water is wholesome and all other aspects of sanitation are satisfactory.

**This certificate is issued subject to the following conditions:**

1. The garbage generated within the premises should be collected and disposed properly in segregated manner.
  2. On any account the garbage should not be burnt.
  3. The pupil should be educated to prevent the usage of plastics in the premises.
  4. Fire precautionary measures should be maintained properly.
  5. Child labour should not be engaged on any account.
  6. Shall not cause nuisance to public as per definition under The Tamil Nadu Public Health Act, 1939.
  7. Class rooms should not be used as passage.
  8. This certificate issued is valid for one year only from the date of issue.
- This certificate is liable to be cancelled at any time on infringement of any of the above conditions or for improper maintenance of the building or toilets in the premises.

Period From: 06.01.2025 to 05.01.2026

Station: NAGERCOIL

*C. Chandrasekara*  
Date: 06.01.2025  
C. CHANDRASEKARA  
PRINCIPAL  
GNANA VIDYA MANDIR  
KEELAKATTUVILAI  
KANYAKUMARI DISTRICT  
PIN. 629501

*R. Rajaramya*  
City Health Officer  
Nagercoil Corporation  
For GNANA VIDYA MANDIR  
Correspondent  
6/1/25



# TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

## DISTRICT WATER TESTING LABORATORY

Asuripallam Medical College Road, Post Office Upstair.

Asuripallam - 629201

Phone: 04652 - 238315

E-mail: jwalabngl@gmail.com

### TEST REPORT

Doc. No: DWTL/FORM/7.8.01

Test Report No: TR/2025/50739-50740

Report Issue Date : 04.06.2025

Invoice Details: 10939 / Dt.29.05.2025

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
8	Appearance	Physical observation	--	Clear	-	-
9	Colour	APHA 23rd Edition 2017 4500 H+B	Hazen	Colourless	Agreeable	Agreeable
10	Odour	IS 3025 Part 5 : 1983	--	None	-	-
11	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
12	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	44	500	2000
13	Conductivity	APHA 23rd Edition 2017 - 2510 B	µS/cm	66	-	-
14	P - Alkalinity	IS 3025-Part 23-1983	mg/L	0	-	-
15	Calcium	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	4	75	200
16	Magnesium	APHA 23rd Edition 2017- 3500 Mg B	mg/L	0	30	100
17	Iron	APHA 23rd Edition 2017- 3500 Fe B	mg/L	0.12	0.3	1
18	Manganese	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	0.00	0.1	0.3
19	Ammonia	APHA 17th Edition-1989- 4500 NH3C	mg/L	0.04	0.5	0.5
20	Nitrite as NO <sub>2</sub>	APHA 23rd Edition 2017- 4500-NO2 B	mg/L	0.01	-	-
21	Total Phosphate as PO <sub>4</sub>	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0.10	-	-
22	Tidys	APHA 23rd Edition 2017 - 4500 O - B	mg/L	0.26	-	-
23	Residual Chlorine as RC	IS / APHA	mg/L	0	0.2	0.2
24	Feecal Coliform	IS / APHA	CFU / 100 ml	0	0	0

**Remarks :** The above water sample confirmed to IS 10500-2012 drinking water specification. With respect to above tested parameters, the water is chemically potable and bacteriologically safe.

.....End of the report

FOR GNANA VIDYA MANDIR

R. Rajaramya  
Correspondent

C. Chandrakala  
C. CHANDRAKALA  
PRINCIPAL  
GNANA VIDYA MANDIR  
KEELAKATTUVILAI  
KANYAKUMARI DISTRICT  
PIN: 629 501

C. Ananthi - Assistant Executive Engineer